



EC CERTIFICATE

Notified Body No. 0843

CPR Notified Body, UL International (UK) Ltd., Wonersh House, The Guildway, Old Portsmouth Road, Guildford, Surrey, GU3 1LR, United Kingdom

Certificate of constancy of performance 0843-CPR-0284

In compliance with the Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

K-FIRE Sealant A Plus

Penetration Seal and Linear Joint Seal Classified for use in flexible walls, solid walls and solid floors

A sealant used to seal around cables and metallic pipes to form a penetration seal to reinstate the fire resistance performance of wall and floor constructions, where they have been provided with apertures for the penetration of services. The sealant may also be used to seal linear gaps and joints in and between wall and floor constructions to reinstate the fire resistance performance of wall and floor constructions, where they abut or include gaps. K-FIRE Sealant A Plus is supplied in liquid form contained within 310 ml cartridges, 600ml foils or in 5, 10, 15 or 19 litre tubs. The sealant is gunned or trowelled into the aperture in or between the separating element/elements and where appropriate around the service or services, to a specified depth utilising various backing materials.

produced by

L' ISOLANTE K-FLEX UK Ltd
Unit 9 Coalville Business Park,
Jackson Street
Coalville
Leicestershire
LE67 3NR

and produced in the manufacturing plant(s)

A/001

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in the ETA:

ETA 15/0818 & ETA 15/0795

under system AVCP 1 for the performance set out in this certificate are applied and that

K-FIRE Sealant A Plus fulfils all the prescribed requirements for these performances.

This certificate was first issued on 4th December 2015 and will remain valid as long as the ETA remains valid and the manufacturing conditions in the plant or the factory production control itself are not modified significantly, unless suspended or withdrawn by the product certification body.

First issue date: 4th December 2015

Signature:

Chris Miles
for
UL International (UK) Ltd.



EC CERTIFICATE

Notified Body No. 0843

CPR Notified Body, UL International (UK) Ltd., Wonersh House, The Guildway, Old Portsmouth Road, Guildford, Surrey, GU3 1LR, United Kingdom

Annex: Detailed information sheet

Certificate Number: 0843-CPR-0284

Product/Device description:

K-FIRE Sealant A Plus

Applicant designation:

L' ISOLANTE K-FLEX UK Ltd
Unit 9 Coalville Business Park,
Jackson Street
Coalville
Leicestershire
LE67 3NR

Product Information:

K-FIRE Sealant A Plus

The referenced product complies with:

A – All the relevant requirements as per ETA 15/0818 & ETA 15/0795 issued 4th December 2015

A handwritten signature in blue ink, appearing to read 'Chris Miles', enclosed in a circular scribble.

Chris Miles
for
UL International (UK) Ltd.